



Chemical & Bact. Examination Report

Date: 13-7-26

No. : Lab./JR.CH./PHED/TECH/2026-27/134

To,

Delphi Premier School
Chhatarpura Bundi


Sample Taker: Rasinder Pal Singh

Ref. No- --Nil

Dated:- 08.07.26

S. No.	C.L.R. No.	Name of City / Village	Date of Collection	Date of receipt	Source	Particulars of Source	pH	Alk.	T.H.	Cl	No ₃	F	TDS	Turbidity	Colour	Odour	B.L.R. No.	Total Coliform	Residual Chlorine
Desirable Limit							6.5 to 8.5	200	300	250	45	1.0	500	1	5	Agreeable		NIL	
Permissible Limit in absence of alternate source							No. relaxation	600	600	1000	45	1.5	2000	5	15	Agreeable		NIL	
1	163	Bundi	08.07.26	08.07.26	TW	Delphi Premier School NH-52 Opp. Reliance Petrol pump Chhatarpura Bundi	7.66	320	530	380	34	0.976	1368	1.12	ND	Agreeable	442	Nil	Nil

Remark:- Sample Not Collected By Lab


Junior Chemist
PHED Laboratory Bundi